
Read Nfpa 20 2007

Downloaded from
Read Nfpa 20 www.whlarchitecture.com
2007 by Shelton & Lopez

INTRODUCTION

Fire protection systems are the backbone of building safety, and at the heart of many such systems lies the fire pump. The standard that governs the installation, performance, and testing of these pumps is NFPA 20, and for those working with the 2007 edition, understanding its nuances is critical. When engineers, contractors, and code officials decide to **read NFPA 20 2007**, they are not merely reviewing a document; they are ensuring that a building's life safety

infrastructure meets rigorous, time-tested requirements. This edition, while superseded in later years, remains a reference point for many existing installations and jurisdictions that have not updated their codes. In this article, we will explore the essential components of the NFPA 20 2007 standard, how to navigate its chapters, and why mastering its content is vital for any fire protection professional.

UNDERSTANDING THE SCOPE OF NFPA 20 2007

What is NFPA 20?

NFPA 20, officially titled “Standard for the Installation of Stationary Pumps for Fire Protection,” is published by the National Fire Protection Association. It provides minimum requirements for the selection, installation, and testing of fire pumps, drivers, controllers, and associated equipment. The standard covers everything from centrifugal and vertical turbine pumps to positive displacement pumps, ensuring that they deliver adequate water flow and pressure to sprinkler and standpipe systems during a fire emergency.

The 2007 edition

represents a specific snapshot of this evolving standard. It was developed through a consensus process involving industry experts, and it incorporates changes and clarifications from earlier editions. For anyone who must **read NFPA 20 2007**, the document is a complete blueprint for designing reliable fire pump installations that comply with accepted safety practices.

Why the 2007 Edition Still

Matters

Even though newer editions exist, many local and state codes adopt specific editions and may not update immediately. Facilities built under the 2007 requirements continue to operate, and maintenance personnel must understand the original design basis. Additionally, the 2007 edition introduced important revisions related to engine-driven pumps, suction piping, and the calculation of net positive suction head (NPSH). For engineers involved in retrofits or upgrades, the ability to **read NFPA 20 2007** fluently is a prerequisite for evaluating existing systems and planning modifications that

remain compliant.

KEY

REQUIREMENTS IN NFPA 20 2007

Fire Pump Types and Drivers

NFPA 20 2007 categorizes fire pumps based on their design and application. Centrifugal pumps are the most common, and the standard details their performance curves, casing pressure ratings, and shaft sealing methods. The document also specifies requirements for drivers, including electric motors and

diesel engines. For example, diesel engine drivers must be equipped with a reliable starting system, cooling provisions, and a day tank that holds enough fuel for a predetermined run time (typically 8 hours at full load).

The standard also addresses the mounting of pump and driver on a common baseplate, alignment tolerances, and vibration isolation. When you **read NFPA 20 2007**, you will find clear tables and figures that guide the selection of pump materials based on the water quality and pressure demands. Stainless steel impellers and bronze fitted pumps are often recommended, but the standard provides

criteria for making these decisions.

Pump Location and Installation

One of the most critical sections of NFPA 20 2007 concerns the pump room location. The standard requires that fire pumps be housed in a room that is protected from fire, separated from other building areas by fire-resistance-rated construction. The room must have adequate drainage, lighting, and ventilation. Additionally, the pump must be installed so that it is accessible for

inspection, maintenance, and operation. The standard explicitly states that the pump room should not be used for storage, ensuring that equipment remains unobstructed during an emergency.

For those who **read NFPA 20 2007** closely, the installation details also include minimum clearances around the pump and driver, the location of suction and discharge gauges, and the proper placement of relief valves. These provisions prevent damage from water hammer and ensure safe operation at all flow conditions.

Water Supply and Suction

No fire pump can function without a reliable water source. NFPA 20 2007 mandates that the water supply – whether from a public water main, a tank, or a natural body of water – must provide sufficient flow and pressure at the pump suction. The standard includes requirements for suction piping to minimize turbulence and avoid vortex formation. It specifies the use of straight pipe lengths, proper sizing (often two sizes larger than the pump suction

flange), and the elimination of unnecessary fittings near the pump inlet.

Another crucial aspect is the calculation of available net positive suction head (NPSHa). The 2007 edition provides guidance on accounting for the effects of elevation, friction losses, and barometric pressure. Failing to compute NPSHa correctly is one of the most common errors in fire pump design. Therefore, anyone who **reads NFPA 20 2007** must pay close attention to the equations and example calculations in this section to ensure cavitation does not occur during operation.

Power Supply and Controller S

Electric motor-driven fire pumps require a dedicated power supply that is separate from normal building loads. NFPA 20 2007 specifies that the pump must be connected to an emergency or standby power source, such as a generator, if the normal power supply is deemed unreliable. The standard details the overcurrent protection, disconnecting means, and the arrangement of conductors to ensure the pump starts

and runs even under fault conditions.

Controllers are another critical element. The 2007 edition addresses listed fire pump controllers that include automatic start and stop functions, manual shut-off, and status indicators. For diesel engine pumps, the controller must monitor engine temperature, oil pressure, and battery voltage. When you **read NFPA 20 2007** on controllers, you will see requirements for the recording of run time and the means to simulate a power failure to test the automatic start sequence.

Testing

and Maintenance

NFPA 20 2007 does not end at installation; it also includes requirements for acceptance testing and periodic performance testing. The acceptance test is conducted on site and must demonstrate that the pump meets its rated flow, pressure, and capacity. The test typically involves running the pump at churn (no flow), at 100% rated flow, and at 150% of rated flow, while recording suction and discharge pressures.

For ongoing reliability, the standard recommends weekly

and monthly inspections, as well as annual flow tests. Those who **read NFPA 20 2007** will find checklists for lubricating bearings, checking packing gland leakage, testing the diesel engine starting batteries, and verifying that the pump can start automatically upon a pressure drop. Adhering to these maintenance schedules extends the life of the equipment and ensures readiness.

HOW TO READ NFPA 20 2007 EFFECTIVELY

Understa nding the

Chapter Structure

NFPA 20 2007 is organized into chapters that follow a logical sequence. Chapter 1 covers administration (scope, purpose, and enforcement). Chapter 2 provides referenced publications. Chapter 3 offers definitions. The technical substance begins with Chapter 4, which addresses general requirements. Subsequent chapters focus on pumps (Chapter 5), drivers (Chapter 6), controllers (Chapter 7), and installation (Chapter 8). Annex A contains explanatory material that is not mandatory but provides invaluable context.

When you **read NFPA 20 2007**, it is helpful

to start with the definitions in Chapter 3, as they clarify terms like “approved,” “listed,” and “rated capacity.” Then, move through the chapters systematically, noting that many requirements are interrelated. For example, the sizing of the pump suction pipe (Chapter 5) is referenced in the water supply requirements (Chapter 4).

Using Annexes and Appendic es

Annex A is the most used part of the standard after the

main text. It contains additional explanations, diagrams, and examples that illustrate the intent of specific code sections. For instance, Annex A includes a detailed flowchart for determining when a fire pump is required, and it provides sample calculations for NPSH and pump horsepower. Make sure to read the annexes when you **read NFPA 20 2007**, as they often reveal the “why” behind a rule, which makes compliance easier and more accurate.

Common Interpreta

tion

Challenge

workshops, or consult with a fire protection engineer who is experienced with this edition.

S

One common difficulty is reconciling the requirements for electric motor drivers with the requirements for diesel engines—each has its own set of thresholds for starting, cooling, and fuel supply. Another challenge is understanding the allowed exceptions for very large pumps (e.g., those over 2,500 gpm). The 2007 edition also includes special rules for pumps driven by steam turbines, a technology that was still in use at the time. To navigate these complexities, it is wise to join study groups, attend NFPA

PRACTICAL IMPLICATIONS FOR ENGINEERS AND CONTRACTORS

Compliance and Code Adoption

Because NFPA 20 is referenced by many building codes (IBC, IFC, and NFPA 5000), strict adherence is not optional. A municipal fire marshal may require you to **read NFPA 20 2007** and demonstrate that your installation meets all provisions.

Non-compliance can lead to failed inspections, costly rework, and liability issues. For contractors, understanding the 2007 edition is especially critical when working on buildings that were constructed under that code cycle, as any modification must maintain the original level of protection.

Impact on Design and Budget

The size of the pump, the length of suction piping, and the type of driver directly affect project costs. The 2007 edition requires that engines be located

with sufficient ventilation for combustion, which may demand additional ductwork. Electric motors may require a larger transformer and generator capacity. When you **read NFPA 20 2007** with a critical eye, you can anticipate these cost drivers and incorporate them into the early budget. Moreover, the standard's requirement for a minimum of 2 hours of fire-rated enclosure around the pump room can influence floor plan layouts and structural design.

Another financial consideration is the requirement for listed fire pump controllers, which are more expensive than standard motor controllers. However, using unlisted

components is not permitted under the 2007 edition. Engineers must specify only those products that are included in the manufacturer's listings and approved for fire protection service.

CONCLUSION

NFPA 20 2007 remains a cornerstone document for fire pump installations across numerous existing buildings. Whether you are a design engineer, a contractor, an inspector, or a facility manager, the ability to **read NFPA 20 2007** thoroughly is a skill that directly impacts

life safety. From understanding pump types and suction design to mastering acceptance testing and maintenance schedules, this standard provides clear, enforceable guidance. While newer editions have superseded it in many jurisdictions, the 2007 edition continues to shape the fire protection landscape. Taking the time to study its chapters, annexes, and tables will not only lead to compliant installations but also to safer buildings and better-protected communities.